

## UDC 2000 Configuration Record Sheet

<b>Group Prompt</b>	<b>Function Prompt</b>	<b>Value</b>	<b>Factory Setting</b>
<b><u>LOCK</u></b>	LOCK		CAL
<b><u>LIMIT</u></b>	Lo OR Hi		Hi
	POWRUP		NORM
	HI RNG		1000
	LO RNG		0
	DISPLY		PROC
<b><u>INPUT 1</u></b>	DECMAL		8888
	UNITS		NONE
	IN1 TYP		K H
	IN1 HI		2400
	IN1 LO		0
	BIAS 1		0
	FILTR 1		0
	EMISS		1.0
	BRNOUT		UP
	FREQ		60
	DISPLY		PR N
	LANG		ENGLSH
<b><u>OPTIONS</u></b>	EXTRST		NONE
	AUXOUT		NONE
	0 PCT		0
	100 PCT		1000
<b><u>ALARMS</u></b>	A1S1 VA		90
	A1S2 VA		10
	A1S1TY		PROC
	A1S2TY		PROC
	A1SI HL		HI
	A1S2 HL		LO