

### 4.10 Configuration Record Sheet

Enter the value or selection for each prompt on this sheet so you will have a record of how your controller was configured.

Group Prompt	Function Prompt	Value or Selection	Factory Setting	Group Prompt	Function Prompt	Value or Selection	Factory Setting
<b>LOCK</b>	SECUR	_____	DIS	<b>COM</b>	ComSTA	_____	DIS
	LOCK	_____	CAL		ComADR	_____	0
<b>LIMIT</b>	LOW or HIGH	_____	HIGH	<b>ALARMS</b>	SHDTIM	_____	0
	POWRUP	_____	NORM100		PARITY	_____	ODD
<b>INPUT1</b>	SP MAX	_____	0	BAUD	_____	2400	
	SP MIN	_____	0	TX DLY	_____	1	
	DISPLY	_____	PROC	UNITS	_____	PCT	
	DECMAL	_____	8888	LOOPBK	_____	DIS	
	UNITS	_____	F	A1S1VA	_____	90	
	IN1TYP	_____	KH	A1S2VA	_____	90	
	XMITR1	_____	LIN	A2S1VA	_____	90	
	IN1 HI	_____	2400	A2S2VA	_____	90	
	IN1 LO	_____	1.00	A1S1TY	_____	NONE	
	BIAS 1	_____	0.0	A1S1TY	_____	NONE	
	FILTR1	_____	1.0	A2S1TY	_____	NONE	
	BRNOUT	_____	UP	A2S2TY	_____	NONE	
EMIS	_____	1.0	A1S1HL	_____	HIGH		
FREQ	_____	60	A1S2HL	_____	HIGH		
DISPLY	_____	SP	A2S1HL	_____	HIGH		
<b>OPTIONS</b>	AUXOUT	_____	DIS	A2S2HL	_____	HIGH	
	0 PCT	_____	0	ALHYST	_____	0.0	
	100 PCT	_____	100	ALARM1	_____	NOL	
	EXT RST	_____	DIS	BLOCK	_____	DIS	