

3.11 Options Set Up Group

Function Prompts

Table 3-10 Options Group (Numeric Code 900) Function Prompts

Prompt		Description	Selection or Range of Setting			Factory Setting
English	Numeric Code		Numeric Code	English		
AUXOUT	901	Auxiliary Output	0	DIS	Disabled	DIS
			1	IN1	Input 1	
			2	IN2	Input 2	
			3	PROC	Process Variable	
			4	DEV	Deviation	
			5	OUT	Output	
			6	SP	Setpoint	
			7	LSP1	Local Setpoint 1	
0 PCT	902	Auxiliary Output Low Scaling Factor		Value in Engineering Units		0
100 PCT	903	Auxiliary Output High Scaling Factor		Value in Engineering Units		100
DIG IN	904	Digital Input	0	None		NONE
			1	MAN	To Manual	
			2	LSP	To Local SP 1	
			3	SP2	To Local SP 2	
			4	DIR	Direct Control	
			5	HOLD	Hold SPP/SP Ramp	
			6	PID2	PID Set 2	
			7	RUN	Start a stopped SPP/SP Ramp	
			8	Begn	SPP Reset	
			9	NO I	Inhibit Integral	
			10	MNFS	Manual, Failsafe Output	
			11	LOCK	Keyboard Disable	
			12	TIMR	Start Timer	
			13	TUNE	Start Tune	
			14	INIT	Init SP to PV	
			15	RSP	Remote SP	
			16	MNLT	Latching Manual	
17	TRAK	Output tracks Input 2				
DI COM	905	Digital Input Combinations	0	DIS	Disabled	DIS
			1	+ PD2	PID Set 2	
			2	+DIR	Direct	
			3	+SP2	Set Point 2	
			4	+SP1	Set Point 1	
			5	+RUN	Start SPP	