

Appendix A

Meaning of the "C" codes

NOTE: "C" appears in the PROG display, the number appears in the SEG display, and the data for the code appears in the shared display.

Code	Meaning
C01	Upper limit for the controller output of PID1.
C02	Lower limit for the controller output of PID1.
C03	Upper limit for the controller output of PID2.
C04	Lower limit for the controller output of PID2.
C05	Upper limit for the controller output of PID3.
C06	Lower limit for the controller output of PID3.
C07	Range for the millivolt, volt, or current input.
C08	Upper range limit for the PV units selected for millivolt, volt, or current input.
C09	Lower range limit for the PV units selected for millivolt, volt, or current input.
C10	Cycle time for the time proportional controller output relay.
C11	Hysterisis for the PV and DEV events.
C12	Guaranteed soak band.